

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Monitoring Requirements Not Met for Monument Mountain Regional High School**

The water system sampling requirements were recently not fully met for the 1st and 2nd Quarters of 2022. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor the drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the first month of the quarter in the 1st and 2nd Quarters of 2022 we did not test for a newly required group of compounds called PFAS and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminants we did not properly test for during the 1st and 2nd Quarters of 2022, how often we are supposed to sample for PFAS, how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples will be taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
PFAS	1 sample the 1 st month of 4 consecutive quarters	1	January 2022 and April 2022	July 2022, October 2022, January 2023 and April 2023

What happened? What is being done?

The newly required PFAS testing requirement was not taken in January 2022 or April 2022. The PFAS sample was taken in July 2022 and will be followed by 3 more consecutive quarterly samples in October 2022, January 2023 and April 2023.

For more information, please contact Berkshire Hills Regional School District, 50 Main Street, Stockbridge, MA 01262 (413) 298-4017 x 23.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by [system].

PWS ID#:

Date distributed:

Berkshire Hills Regional School District

1113016

7-22-22